

NOTES:

1. FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES, SEE DWG. E-1. FOR INSTALLATION DETAILS, SEE DWG. E-2. FOR WIRING DIAGRAMS, SEE DWG. E-3 AND DWG. E-4.
2. NOT USED
3. NOT USED
4. SINCE FIRE ALARM CIRCUIT LENGTH IS CRITICAL, ROUTING AND INSTALLATION OF ALL FIRE ALARM CIRCUITS SHALL BE AS SHOWN ON DRAWING. ANY DEVIATION SHALL BE APPROVED BY THE ENGINEER, PRIOR TO INSTALLATION.
5. AVOID ALL AREAS CONTAINING ACM.

THE PORT AUTHORITY
OF NY & NJ

[Signature]
ENGINEERING PROGRAM MANAGER
WORLD TRADE
CHIEF ELECTRICAL ENGINEER

No. Date Revision Approved

ENGINEERING DEPARTMENT

**WORLD
TRADE
CENTER**

ELECTRICAL

Title
**FIRE ALARM SYSTEM
DEVICE UPGRADE
PHASE III
5 WTC 3rd, 4th, 5th & 6th FLOORS**

**5th FLOOR
STROBE LAYOUT
INSTALLATION
SOUTH PART PLAN**


This drawing subject to conditions in Contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

FELDSTEIN APOSTLE A.S.
Designed by Drawn by Checked by

NOVEMBER 26, 1999
Date

WTC-861.573 E-05-4S
Contract Number Drawing Number

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. **WTC-861.573** IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.
DATE *11/10/99* *[Signature]* CENTRAL ENGINEER ARCH
DATE *2/10/00* *[Signature]* ENGINEERING PROGRAM MGR



KEY PLAN
N.T.S.

SCALE IN FEET